

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair

Observed water stained ceiling tiles in classrooms# 129 and 148. Replace ceiling tiles.

Observed missing baseboard and water damage wall in media center. Work order placed however no repair conducted. Work order# 4067322. Investigate water issue and replace baseboard.

Observed missing outlet cover with pipe sticking out in media center. Work order placed however no repair conducted. Work order # 4091005 and 4090747. Replace outlet cover.

Light bulb not operating classroom 143. Replace light bulb.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

Light cover missing in classroom film room # 145. Replace light cover.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Kimberly Henry (913288)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Design & Architect Sr.
Date: 1/14/2020

Inspector Signature:

Handwritten signature of Kimberly Henry.

Client Signature:

Handwritten signature of the client.